

OPTIONAL UPGRADE INFORMATION

Revised 28-Feb-05

The NF3000G3_BootFTPLoader_90_51.fw file is optional for upgrading to System 5. This file will download through DLF-3000 in a shorter time period than the NF3000G3_prog_05_00.fw file and will give the controller the ability to use FTP. After downloading the NF3000G3_BootFTPLoader.fw, the desired firmware version will still need to be downloaded to restore controller operation. (NOTE: If your IT Department has disabled FTP then downloading using FTP will not work.)

1. Use the DLF-3000 utility to download NF3000G3_BootFTPLoader_90_51.fw using the same procedure that is used for PROGRAM upgrades. After downloading NF3000G3_BootFTPLoader_90_51.fw, it must be replaced with the desired firmware version to restore controller operation.
2. Use the DLF-3000 utility or FTP to download the desired firmware version to the controller. Use ProgUserApplFlash_NF3000G3_prog_05_00.bin to download using FTP and NF3000G3_prog_05_00.fw to download using DLF-3000.
(See PL_G3_Firmware_Upgrade_Instructions.pdf on this page for downloading instructions.)